







MCC – forms of separation

See IEC 61439 annex AA or Cap40 brochure

Most common configurations:

- Form 3B, 4A and 4B

Internal separation in accordance with IEC 60439-1

	Form 1	Form 2b	Form 3a	Form 3b	Form 4a	Form 4b
						
Busbars (main + distribution) are separated from functional units		✓	✓	✓	✓	✓
Functional units are separated from other functional units			✓	✓	✓	✓
Terminals are external to functional units			✓	✓		✓
Terminations to functional units are separated from each other			✓		✓	✓
Terminals are separated from the busbars		✓		✓	✓	✓
Capitole 40 supported forms of separation					✓	✓